

CERTIFICATE

Recommendation for Approval: Wastewater pipe system, ductil cast iron

Number	23005
Duration	01.01.2019 – 31.12.2023; issued on 09.01.2019
Owner	Düker GmbH, 97753 Karlstadt, Germany
Product	Wastewater pipe system, ductil cast iron
Application	B, in buildings
Basis	prR 592 012-3:2015, EN 1561, EN 877
Testing Institute	HKL, Stuttgart, Germany
Brand / Type	Düker SML, (details look product site)
Dimension	DN 50 – 300
Coating	Outside: Top coat Inside: Crosslinked epoxy coating
Color	Tubes: Outer red oxide RAL 3009, inside melon yellow RAL 1028 Molded parts: outside and inside oxide red RAL 3009
Connection	Couplings Rapid, stainless
Seals	EPDM and NRB
Test report No.	S.18.P.316.DÜK

Qplus has reviewed the reports prepared by accredited testing institutes and other documents submitted by the manufacturer and has determined that the above products comply with the standards and other requirements of the applicable Qplus guidelines.

Based on the assessment, Qplus can advise interested builders, planners and users to approve these products for use. These products, when properly planned and built-in, fulfil the objectives of the Swiss water protection regulations.